



DEVIATION REPORT – FAX NOTIFICATION FORM
Site Identification No. 177802AAA; FESOP Permit No. 03060057

P.O. Box 227; 4350 West Galena Road; Lena, Illinois 61048
 Phone 815-369-9173; Fax: 815-369-2043

IEPA - Division of Air Pollution
 Control
 Compliance Enforcement Section

IEPA Division of Air Pollution -Peoria

Fax to: (#40) - Springfield
 Fax: 217-782-1875 (Phone 217-782-2113)

Fax to: Field Office
 Fax: 309-671-3024 (Phone 309-693-5463)

Date: 8/14/19 **Time:** 2:30 pm **Operator:** Chris Posey

Federally Enforceable State Operating Permit (FESOP) Condition 3.5 identifies the minimum information required for a deviation report. The information is presented below.

Emission Unit: Fermentation Scrubber & Dryer

Date: 8/5/19 **Start Time:** 11:09 pm **Duration:** varied

Description of Deviation:

At approximately 11:09 pm, the plant lost all electrical power due utility kicking out due to strong thunder storms. Once the utility electric could be reconnected, water flow to the scrubber was restarted at approximately 11:39 pm.

NOTE: Revised report to reflect the addition of ring dryer emissions, which were inadvertently omitted in the 8/13/19 submittal

Effect of Deviation on Compliance:

Loss of water flow to the fermentation scrubber and venting of the dryer to atmosphere before the outlet temperature reached 130 degrees. The distillation scrubber was put online before restarting the process.

Estimate of Excess Emissions:

An estimated emissions report is attached.

NOTE: This emission report has been revised to include ring dryer emissions, which were inadvertently omitted in the 8/13/19 submittal.

Cause of Deviation:

Loss of electrical power from the utility due to strong thunderstorms.

Corrective Action or Preventive Action Taken:

The power was restored as quickly as possible, and water flow was re-established to the scrubber. The turbine was also restarted to provide power to the plant.

Written Follow Up Report To Be Issued: yes no **If you have any questions, please call the Adkins Plant Manager Jason Townsend at 815- 369-9173 ext.245.**